



ELK Engineering Associates Inc.

Specializing In Corrosion & Cathodic Protection Services

**Establishing
a Corrosion Control Program
for a
Large Diameter Concrete Cylinder Water Line**

Presented to
NACE International North Texas Section
by
Earl Kirkpatrick, P.E.


26 September 2012


- **Task 1 – Initial Corrosion Assessment**

Close Interval Survey to define areas of active corrosion.

Active corrosion activity was seen over most reaches of the pipelines.

LINE A - 42" WATER SUPPLY LINE CIPS





The bonding methods shown provide electrical conductivity across the joint and accommodate relative movement due to pipeline settlement. To provide access for welding the bonds, as shown in diagrams A and B, recesses are chipped in the mortar coating as required after field assembly. Separate bonding is not required when joints are field welded.

Figure 12-2 Typical joint bonding details for AWWA C303-type pipe or lined cylinder AWWA C301-type pipe

Description of Lines Under Investigation for Schertz Seguin Local Government Corporation

- **Line A** – 42” diameter, Class 200, RCCP water line from the Nixon Pump Station to the Schertz Booster Pump Station.

This line is 109,040 feet in length with 10 original plus 84 new installed test stations.

- **Line B** – 36” diameter, Class 150 – 250, RCCP water line from the Schertz Booster Pump Station to the Live Oak storage tank facility in Schertz, Texas.

This line is 97,544 feet in length with 9 original plus 75 new installed test stations.


- **Line C** – 30” diameter, Class 150, RCCP water line from Line A station number 973+00 to the Seguin Water Plant.

This line is 19,325 feet in length with 4 original plus 11 new installed test stations.

- **Task 2** – Install 174 additional test stations at locations recommended and described in the previous report. A schedule of recommended test station locations was provided.



Typical test wire cad weld connections at pipe joint.



**Test wire connections
at test station.**




**Typical test wire
connections at casing.**



**Typical test station
installation.**

- **Task 3** - Perform test wire effectiveness tests and pipe continuity tests across the entire length of the pipeline. Should any of the pipe continuity tests reveal a discontinuity between two test points, additional work would be required to locate and repair the ineffective pipe joint bonds.

Typical Concrete Pipe Joint Bonds



Weld Clips



Calculation Example for Theoretical Resistance

42" DIA 10 GA(Class 150)

Rc = Cylinder Resistance

ps = Resistivity of Cylinder Steel, in ohm-cm

Lc = length of cylinder in a pipe section, in feet

Tc = Thickness of cylinder, in inch

D = Outside diameter of steel Cylinder, in inch

Rb = Bond Resistance

Rf = Fringing Resistance

pc = Bond material Resistivity, in ohm-cm

Lb = Length of bonding copper cable

Ab = cross section area of bonding copper cable, steel bar or clip, in square inch

N = number of copper cables, bar or clip

Tc	0.1345	inch	#10 = 0.1345
Lc	1	Feet	
D	43.875	in inch	
ps	0.00003	ohm-cm	

Rc	7.66E-06	ohm per ft
----	----------	------------

Lb	2.5625	inch	
Ab	0.159719	sq inch	Thickness 0.1345
N	3		Width 1.1875
pc	0.00003	ohm-cm	




ELK ENGINEERING ASSOCIATES, INC.
8950 Forum Way
Fort Worth, TX 76140
Phone: 817.568.8585 Fax: 817.568.8590
WEB: WWW.elkeng.com

DATE: 2/29/2012
ELK JOB NO.: 2697
SURVEYED BY: ARB

WEATHER: Cool
Line Designation Line A
STA. NO.: 16750.00
STA. NO.: 15375.00
TOTAL DISTANCE TESTED 1375.00 FT.

PROJECT: Continuity Testing

OWNER: SSLGC



SKETCH

PIPE CONTINUITY TEST

ACTUAL RESISTANCE:

TEST #	LOCATION:					
	I _{ON} (MA)	I _{OFF} (MA)	ΔI	E _{ON} (MV)	E _{OFF} (MV)	ΔE
	1	18.0	18.0	154.0	19.0	135.0
	2					
	3					
Ave	18.0		18.0	154.0	19.0	135.0
R _{TEST} (Based Upon ΔE/ΔI = R)						7.50

THEORETICAL RESISTANCE OF TESTED SEGMENT:

INSERT Pipe Type FROM PULL DOWN LIST

INSERT PIPE SIZE

RESISTANCE OF PIPE DETERMINED BY:

INPUT
42-Inch
MFG

φ

RESISTANCE OF

PIPE/FT 0.00000766 Ohms

RESISTANCE OF JOINT BONDS CALCULATED FROM

BOND WIRE SIZE / TYPE 1 CLIP

RESISTANCE OF BOND 0.0001896 Ohms

LENGTH OF BOND WIRE NA

NUMBER OF BONDS / JOINT 3 Ea.

2

(R_{wire} x L_{wire}) x N_{bonds/joint} = Calculated Bond Resistance

Calculated Bond Resistance 0.0001896 Ohms

$$R_{THEOR.} = (L_{PIPE} \times R_{PIPE}) + (N_{JOINTS} \times R_{JOINTS})$$

$$\therefore R_{THEOR.} =$$

$$((1375.00 \text{ FT.} \times 0.0000077 \text{ OHMS/FT.}) + (45 \times 0.0001896 \text{ Ohms})) = 0.0190645 \text{ Ohms}$$

ACCEPTANCE:

IF R_{TEST} IS LESS THAN OR EQUAL TO 1.15 TIMES R_{THEOR.} THE PIPELINE SEGMENT IS ELECTRICALLY CONTINUOUS

$$R_{TEST} \leq 115\% \times R_{THEOR.} \quad 115\% \times 0.0190645 \text{ Ohms} = 0.0219242 \text{ Ohms}$$

$$R_{TEST} = 7.50000 \text{ Ohms} \quad \& \quad 115\% R_{THEOR.} = 0.0219242 \text{ Ohms}$$

CONCLUSION

THIS PIPELINE SEGMENT IS NOT ELECTRICALLY CONTINUOUS

Results of Continuity Testing

- **Line A** – 83 pipe spans only 50 could be tested
48 failed 96% failed
2 passed 4% passed
- **Line B** – 71 pipe spans only 62 could be tested
61 failed 98.39% failed
1 passed 1.61% passed
- **Line C** – 10 pipe spans only 8 could be tested
7 failed 87.5% failed
1 passed 12.5% passed







Cathodic Protection (CP) Can Mitigate Future Corrosion Failures

Galvanic Anode CP

Pro: Simple Systems

Minimum routine
monitoring

Con: Digging every other
joint

ROW damage/land owner
issues

Impressed Current CP

Pro: Less costly than GACP
for continuous pipe

Fewer excavations

Con: Will require extensive
digs

Time and labor required
to locate digs

ROW Damage/land
owner issues

Both Approaches: Multi year construction program

The Way Forward

- SSLGC should designate the Highest Consequence Area (HCA) pipe section for further investigation
- Select a short segment within the HCA with no ROW issues for detailed evaluation by ELK
- ELK working with contractor to locate and bond discontinuities and gather data for CP design
- ELK to conduct design survey over all of pipelines A,B, and C
- Design report to provide:
 - **Determination of CP type: GACP or ICCP**
 - **Further assessment of all 3 pipelines**
 - **Design details**
 - **Costs**
 - **Suggested/recommended construction schedule**
- Construction and commissioning of recommended system

QUESTIONS



ELK Engineering Associates Inc.

Specializing In Corrosion & Cathodic Protection Services